


DEMO UNDERGROUND STORAGE TANK VOLUME CALIBRATION REPORT

Report done by PT. SURYA KWON SUNG



For


CLIENT

3/12/2025




Volume from Elevation

Direction: X= 0 m ; Y= 0 m ; Z= 1 m



1 : 59 | 1.2 m





Elevation (m)	Volume over (m³)	Volume under (m³)
0.000	30.9910	0.0117
0.100	30.5449	0.4579
0.200	29.7940	1.2088
0.300	28.8472	2.1557
0.400	27.7501	3.2529
0.500	26.5313	4.4717
0.600	25.2114	5.7917
0.700	23.8083	7.1948
0.800	22.3384	8.6648
0.900	20.8160	10.1872
1.000	19.2545	11.7488
1.100	17.6662	13.3372
1.200	16.0626	14.9408
1.300	14.4541	16.5494
1.400	12.8514	18.1522
1.500	11.2661	19.7375
1.600	9.7110	21.2926
1.700	8.1997	22.8040
1.800	6.7460	24.2578
1.900	5.3650	25.6388
2.000	4.0733	26.9306
2.100	2.8893	28.1147
2.200	1.8357	29.1683
2.300	0.9461	30.0580
2.400	0.2776	30.7266